



**ఆంధ్రప్రదేశ్ రాజ పత్రము**  
**THE ANDHRA PRADESH GAZETTE**  
**PUBLISHED BY AUTHORITY**

**PART I EXTRAORDINARY**

**No.198**

**AMARAVATI, TUESDAY , MAY 9, 2017**

**G.83**

**NOTIFICATIONS BY GOVERNMENT**

--X--

**ENERGY DEPARTMENT**  
**(Power.II)**

THE ELECTRICITY ACT, 2003 - REGULATION 36 OF CENTRAL ELECTRICITY  
AUTHORITY (MEASURES RELATING TO SAFETY AND ELECTRIC SUPPLY)  
REGULATIONS, 2010.

*[G.O.Ms.No.10, Energy (Power.II), 3<sup>rd</sup> May, 2017.]*

**NOTIFICATION**

In supersession of the earlier G.O's issued on the above subject and in exercise of the powers conferred by the Regulation 36 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010, the State Government hereby specifies that all installations of Voltage of Supply Exceeding 11KV at the Point of Commencement of supply (irrespective of connected load) of Multi-Storied Buildings of more than Fifteen (15) Metres in height, shall be inspected by the Electrical Inspector.

For Industries, Chief Electrical Inspector to Government (CEIG) inspection shall only be for voltage levels of 132 KV and above.

**AJAY JAIN,**  
*Principal Secretary to Government.*

---X---